

Landlord Gas Safety Record

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure.

| Cor | npany / I | nstaller | r | | | Job Addı | ress | | | | | | Customer / | Landlord | | | | | |
|--|-------------------|-------------------------|--------------------|----------------------------|-------------------|-------------------|--------------|-------------------------|---------------------|------------------------------|-------------------|--|---------------------------|---|--|--|---|-----------------------|--------------------------|
| Engineer | | Simon Carter | | | | Name Tenant - | | | | | | | | Mr Bill Voisey | | | | | |
| Company | | All Aspects Heating Ltd | | | | Address | 57 | 57 | | | | | Company Address | | | | | | |
| Address | | 61 Walnut Close | | | | | Br | Brentford Road | | | | | | 76 | | | | | |
| | | | | | | | Bir | Birmingham | | | | | | Chesterwood Road | | | | | |
| | | Birmingham | | | | Post Code B14 4DG | | | | | | | | Birmingham | | | | | |
| Post Code | | D.27 70T | | | | Tel. No | e B1 | .4 4DG | | | | | | B13 0QE | | | | | |
| Tel No. | | B37 7PT | | | | Tel. NO | | | | | | | Post Code Tel. No | 01214412364 | | | | | |
| Gas Safe Reg | | 0121 243 3977 217817 | | | | | | | | | | | | 012144125 | 0-1 | | | | |
| ID Card No. | | 5449159 | | | | | | | | | | | | | | | | | |
| | | 5445153 | 5 | | | | | | | | | | | | | | | | |
| Арр | liance D | etails | | | | | | Inspec | tion Details | | | | | | | | | | |
| Location | | on Appliance Type | | Make | Mode | el | Flue Type | Landlord's Appliance | Appliance Inspected | Operating Pressure (mbar) | Heat Input (kW/h) | High Combustion Reading Ratio CO (| Reading CO2 Ratio CO C | correct operation |) Ventilation Provision satisfactory | Visual condition of flue and termination satisfactory | Flue Performance test | Appliance Serviced | Appliance safe to use |
| 1 | Bathroo | om C | Combination Boiler | Worcester Bosch | Greenstar 2 | 28i Junior | RS | Yes | Yes | 19.6 | 26.7 | o.0005 50 9 | % ppm % 9.7 0.0000 3 8 | | Yes | Yes | Pass | Yes | Yes |
| 2 | Cupboa Kitcher | | Cooker | New World | Newho | ome | FL | Yes | Yes | 21 | 11.5 | ΝΔ ΝΔΙ | NA NA NA N | A Yes | Yes | NA | NA | No | Yes |
| 3 | Riceriei | | | | | | 16 | 103 | 105 | 21 | 11.5 | | | | 103 | 110 | NА | NO | 163 |
| 4 | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | |
| Def | ects / Ide | entified | | | | | | | | Labels a | nd Warning No | otice Issued | CO Alarm(s |) | | Smoke | Alarm(s) | | |
| | 1 | | | | | | | | | | NA | | | | | | | | |
| | 2 3 | No stability chain. | | | | | | | | | NA | | | CO Alarm(s) fitted Yes | | | Smoke Alarm(s) fitted Yes | | |
| 4 | | | | | | | | | | | | | | CO Alarm(s) tested and Satisfactory Pass | | | Smoke Alarm(s) tested NA and Satisfactory | | |
| 5 | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| Eme | ergency Co | ntrol Acce | essible Yes Gas | Tightness Satisfactory Yes | 5 | Comr | ments | | | | | | | | | | | | |
| Gas Installation Pipework Visual Inspection Satisfactory Yes | | | | | | | | | | | | | | | | | | | |
| Equipotential Bonding Yes | | | | | | | | | | | | | | | | | | | |
| Water quality/level of inhibitor acceptable No | | | | | | | | | | | | | | | | | | | |
| NEXT INSPECTION DUE ON OR 22-Apr-2025 BEFORE | | | | | | | | | | | | | | | | | | | |
| Sigu | natures | | | | | | | | | | | | | | | | | | |
| | ied by: | | | | Received S by: | Signed | ed | | | | | Date 22-Apr-2024 | | | | | | | |
| Prin | t Name | Simon Carter F | | | | Print Name | t Name Chris | | | | | | | | | | | | |